



Town of Fort Myers Beach

CODE COMPLIANCE

2525 Estero Blvd Fort Myers Beach, Florida 33931  
Phone: (239) 765-0202 Fax: (239) 765-0591

# STOP WORK NOTICE

## BUILDING SAFETY SERVICES

This construction has been inspected and is in violation of **THE FLORIDA BUILDING CODE**. Please correct as noted below before any further work is done.

### DO NOT REMOVE THIS NOTICE

<b>Owner:</b>	<b>Kim Davidson</b>
<b>Address:</b>	<b>3115 Estero Blvd</b>
<b>Case #:</b>	<b>TBD</b>

**Code Violation:** Town of Fort Myers Beach LDC, Chapter 6 Section 111: Adoptions; amendments, adopting the Florida Building Code as amended. Florida Building Code section:

**107.3.1** When the *building official* issues a *permit*, the *construction documents* shall be *approved*, in writing or by stamp, as "Reviewed for Code Compliance." One set of *construction documents* so reviewed shall be retained by the *building official*. The other set shall be returned to the applicant, shall be kept at the site of work and shall be open to inspection by the *building official* or a duly authorized representative.

**Violation:**

**Work not done according to approved plans**

**Work Witnessed (Description):**

**House collapse due to improper foundation installed.**

**Corrective Action:**

**Permit is revoked. New permit must be applied for showing corrective action designed by a Florida licensed architect or engineer.**

Date: 10/16/2024

Inspector 

Email: Buildingpermits@fmbgov.com



# Town of Fort Myers Beach

## CODE COMPLIANCE

2525 Estero Blvd Fort Myers Beach, Florida 33931  
Phone: (239) 765-0202 Fax: (239) 765-0591

### REMOVE AND BRING THIS SHEET WITH YOU

<b>Owner:</b>	<b>Kim Davidson</b>
<b>Address:</b>	<b>3115 Estero Blvd</b>
<b>Case #:</b>	<b>TBD</b>

**Code Violation:** Town of Fort Myers Beach LDC, Chapter 6 Section 111: Adoptions; amendments, adopting the Florida Building Code as amended. Florida Building Code section:

**107.3.1** When the *building official* issues a *permit*, the *construction documents* shall be *approved*, in writing or by stamp, as "Reviewed for Code Compliance." One set of *construction documents* so reviewed shall be retained by the *building official*. The other set shall be returned to the applicant, shall be kept at the site of work and shall be open to inspection by the *building official* or a duly authorized representative.

**Violation:**

**Work not done according to approved plans**

**Work Witnessed (Description):**

**House collapse due to improper foundation installed.**

**Corrective Action:**

**Permit is revoked. New permit must be applied for showing corrective action designed by a Florida licensed architect or engineer.**

Date: 10/16/2024

Inspector

Email: [Buildingpermits@fmbgov.com](mailto:Buildingpermits@fmbgov.com)